



**BUREAU  
VERITAS**

# Attestation of Conformity

**Certificate No.:** 2288AP110114001  
**Equipment:** Solar (PV) Grid Inverter  
**Brand Name:**   
**Test Model No.:** CPS SCA 30KTL-T/SA, CPS SCA 36KTL-T/SA  
**Applicant:** Shanghai Chint Power Systems Co., Ltd  
No. 3255, Sixian Rd, Songjiang District, 201614 Shanghai, P.R. China  
**Report No.:** PV2211WDG0114-1, PV2211WDG0114-2

## Use in accordance with regulations:

The inverters are tested for functional safety, grid protection and efficiency. For detailed information, please watch the corresponding test reports.

## Applied rules and standards

IEC 61727:2004	Photovoltaic (PV) systems – Characteristics of the utility interface
IEC 62116:2014	Utility-interconnected photovoltaic inverters – Test procedure of islanding prevention measures

  
**Name: Daniel Yu**  
**Manager / New Energy Team**  
**Date: 2022-11-23**

This document shall not be reproduced, except in full, without the written approval of Bureau Veritas Shenzhen Co., Ltd. Dongguan Branch.  
Information given in this document is related to the tested specimen of the described electrical sample.